

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF EDMONSON COUNTY)	
WATER DISTRICT FOR A DEVIATION FROM 807)	CASE NO. 94-297
KAR 5:066, SECTION 10(2)(A), REGARDING)	
CONSTRUCTION REQUIREMENTS)	

O R D E R

On August 1, 1994, Edmonson County Water District ("Edmonson County") applied for a deviation from Commission Regulation 807 KAR 5:066, Section 10(2)(a), to accept ownership and operate approximately 3,000 feet of existing two-inch water main. Commission Regulation 807 KAR 5:066, Section 10(2)(a), establishes the maximum length of individual small pipe.

Having reviewed the evidence of record and being otherwise sufficiently advised, the Commission finds that:

1. Edmonson County desires to accept ownership and operate approximately 3,000 linear feet of two-inch water main which presently serves Ernest Brooks.

2. Commission Regulation 807 KAR 5:066, Section 10(2)(a), prohibits individual non-circulating small pipe of two inch nominal size from exceeding 250 feet in length, but permits deviations from this prohibition for rural water lines which comply with the requirements of Commission Regulation 807 KAR 5:066, Section 5(1), and can provide adequate water flow to serve its customers' peak requirements.

3. Edmonson County has filed information that indicates that adequate service is presently being provided on this 2-inch water line and that as many as five customers may be served from this water line.

IT IS THEREFORE ORDERED that:

1. Edmonson County is granted a deviation from Commission Regulation 807 KAR 5:066, Section 10(2)(a), for the 3,000 linear feet of water main presently serving Ernest Brooks. This deviation is contingent upon this water main providing adequate and reliable service in compliance with all other Commission regulations.

2. Edmonson County shall monitor the adequacy of this water main. If the level of service on this water main is inadequate or declining, or its water pressure is outside the limits of Commission Regulation 807 KAR 5:066, Section 5(1), Edmonson County shall take necessary actions to maintain the level of service within the standards set forth in Commission regulations.

3. Edmonson County shall provide service on this water main or any other water main to any customer who is entitled to service under Commission regulations and Edmonson County's tariff.


4. No further extension of or lateral connection to the water main presently serving Ernest Brooks shall be made unless a minimum of three-inch water line is used.


5. Edmonson County shall construct no further extension or lateral to the water main presently serving Ernest Brooks until


appropriate engineering studies are performed and all requisite approvals are obtained.

Done at Frankfort, Kentucky, this 22nd day of August, 1994.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director